



Please note that this test/result is issued to you on an INDICATION ONLY basis as tests are conducted on a particular shade/production, not necessarily the material you would be receiving.

Olympic Tiles Pty Ltd will not be held responsible for the item not meeting this result.

It is the responsibility of the end user to carry out appropriate testing for the tiles intended use.

Slip Check to AS 4586:2013

Abstract / 30

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports

Safe Environments Pty Ltd Unit 4, 40 Bessemer Street, Blacktown NSW 2148 Australia T (+61) (2) 9621 3706 F (+61) (2) 9621 8891 ABN 80 118 534 768 www.SafeEnvironments.com.au info@safeenvironments.com.au



12 October 2016

Test Report No. R12344b

Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.

Requested by: Client Address:	Olympic Tiles Pty Ltd 1265 The Horsley Drive Wetherill Park NSW 2164		
Product Manufacturer:	Supplied by Olypmic Tiles		
Product Description:	Abstract / 30		
Test conducted according to: Location: Conducted by:	AS 4586:2013 Appendix A Slip Check Pty Ltd Test Fac Dale Rowell	ilities, Blacktown	NSW 2148
Date:	12 October 2016	Temperature:	22°C
Sample:	Unfixed	Cleaning:	None
Rubber slider used:	Slider 96	Conditioned:	Grade P 400 paper dry followed
Slope of specimen:	Tested on a flat level surface		by wet lapping film
Direction of Test:	NA		

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	32	32	29	30	28

Reported SRV of Sample:	30
Class:	P2

ACCREDITED FOR TECHNICAL COMPETENCE

Ryan Voorderhake Technician

Please note that this test/result is issued to you on an INDICATION ONLY basis as tests are conducted on a particular shade/production, not necessarily the material you would be receiving.

Olympic Tiles Pty Ltd will not be held responsible for the item not meeting this result.

It is the responsibility of the end user to carry out appropriate testing for the tiles intended use.

4/40 Bessemer Street Blacktown NSW 2148 Phone 02 9621 3706 ABN 80 118 534 768