

GRIPTEK ANTI-SLIP SOLUTIONS PTY LTD 26a Production Avenue Kogarah NSW 2217 AUSTRALIA ABN: 13 622 802 797 T. 1300 01 GRIP E. info@griptek.com.au

| Test Report No: | 140324A | | | |
|--------------------------------|---|---|---|--|
| Slip Resistance Measurement of | New Pedestrian Surfaces: AS4586:2 | 013 Appendix A | | |
| Client: | Olympic Tiles Pty Ltd - 1265 The Horsley Drive, Wetherill Park NSW 2164 | | | |
| Test Date: | 14/03/2024 | Temperature: | 27 Deg. C | |
| Test Conducted to: | AS 4586:2013 Appendix A | Conducted by: | Sean C Murphy B.A (U Syd.), Dip. Ed | |
| Test Method: | Wet Pendulum Testing | Test Device: | Munro - Reg. No. 2015 Calibration Exp. 11/1/2025 | |
| Surface: | Focus/Kimberley SR | Rubber Slider Use d: | Slider 96 (4 S Rubber) | |
| Slider Preparation: | 30x30/30x60cm Abrasive paper, Grade P400 followed | l by pink lapp <mark>ing</mark> paper w | Cert. No. 22/23, Batch # 21 | |
| Test Location: | 1265 The Horsley Drive, Wetherill Pa | rk NSW 216 <mark>4</mark> | | |
| Surface Preparation: | Cleaned with Water & Hand Scrubbin | g | | |
| Surface Application: | N/A. | | | |

Tested Area:

| Specimen Number | Location | Condition | Gradient % | Direction of Test | Mean BPN Last 3 swings |
|--------------------|--------------|-----------|---------------|-------------------|---------------------------|
| 1 | Loose Sample | As Found | <2.0 | N/A | 50 |
| 2 | Loose Sample | As Found | <2.0 | N/A | 55 |
| 3 | Loose Sample | As Found | <2.0 | N/A | 50 |
| 4 | Loose Sample | As Found | <2.0 | N/A | 53 |
| 5 | Loose Sample | As Found | <2.0 | N/A | 51 |

Mean BPN Slip Resistance Value - SRV 52

Classification P4

Low

Contribution to Risk

The AS 4586 standard provides a guide & recommendation for use, we recommend that this report be read in conjuction with AS 4586 & Handbook HB198: 2014. Refer to Table 3B of HB 198 for requirements of sloped surfaces & ramps. The results in this test do not account for any future wear, contamination or maintenance of this surface. GripTek Anti-Slip Solutions Pty Ltd or our agents, licencees or employees accept no responsibility for any actions whatsoever which may arise as a result of this test report, all information within this report is copyright & is protected by copyright law.

Please note that this test/result is issued to you on an INDICATION ONLY basis as tests are conducted on a particular shade/production, not necessarily the material you would be receiving. Olympic Tiles Pty Ltd will not be held responsible for the item not meeting this result. It is the responsibility of the end user to carry out appropriate testing for the tiles intended

| Interpretation of the Wet Pendulum Results | | | | | |
|---|----------|--|--|--|--|
| Classification of pedestrian surface materials according to the AS 4586 | Mean BPN | | | | |
| P5 | >54 | | | | |
| P4 | 45-54 | | | | |
| P3 | 35-44 | | | | |
| P2 | 25-34 | | | | |
| P1 | 12-24 | | | | |
| P0 | <12 | | | | |

Approved Signatory:

Michael Holt

tYOU