



Please note that this test/result is issued to you on an INDICATION ONLY basis as tests are conducted on a particular shade/production, not necessarily to material you would be receiving. Olympic Tiles Pty Ltd will not be held responsible for the item not meeting this result. It is the responsibility of the end user to carry out appropriate testing for the tiles intended use.

## Slip Check to AS 4586:2013 60 x 60 Cordoba Moka STCB6003

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports



A division of Safe Environments Pty Ltd www.SafeEnvironments.com.au

4/40 Bessemer Street Blacktown NSW 2148 Phone 02 9621 3706 ABN 80 118 534 768

11 March 2016

## Test Report No. R10489

## Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.

Requested by:

Olympic Tiles Pty Ltd

Client Address:

1265 The Horsley Drive

Wetherill Park NSW 2164

Product Manufacturer:

Starstiles

Product Description:

60 x 60 Cordoba Moka STCB6003

Test conducted according to:

AS 4586:2013 Appendix A

Location:

Slip Check Pty Ltd Test Facilities, Blacktown NSW 2148

Conducted by:

Dale Rowell

Date:

11 March 2016

Temperature:

28°C

Sample:

Unfixed

Cleaning:

Vone

Rubber slider used:

Slider 96

Conditioned:

Grade P 400 paper dry followed

Slope of specimen:

Tested on a flat level surface

by wet lapping film

Direction of Test:

NA

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	30	29	30	31	30

Reported SRV of Sample:	30
Class:	P2

Please note that this test/result is issued to you on an INDICATION ONLY basis as tests are conducted on a particular shade/production, not necessarily to material you would be receiving. Olympic Tiles Pty Ltd will not be held responsible for the item not meeting this result. It is the responsibility of the end user to carry out appropriate testing for the tiles intended use.



Martin Daniel

Materials Scientist

Safe Environments Pty Ltd R10489 - Slip Check, 60 x 60 Cordoba Moka STCB6003 11 March 2016

Page 2 of 2